

NOTIFICATION OF TEST RESULTS

Issued to: ETI Elektroelement d.o.o.
Obrezija 5, SI-1411 Izlake, Slovenia

For the product: Built-in switch

Trade name: ETI

Type/Model: SV

Manufactured by: ETI Polam Sp. z o.o.,
Al. Jana Pawła II 18, 06-100 Pułtusk, Poland

Ratings: $I_e = 16\text{ A}, 25\text{ A}, 40\text{ A}$, $U_e = 230\text{ V (1p)}, 400\text{ V (2p, 3p, 4p)}$, AC-23B,
 $U_i = 440\text{ V}$, $U_{imp} = 4\text{ kV}$, $I_{cw} = 600\text{ A} - 1\text{ s}$, $I_{cm} = 500\text{ A}$

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard
EN 60947-3:2008, AMD1:2012, AMD2:2015

As shown in the Test Report
2237509.50


This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body, which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body.

Arnhem, 28 April 2020

Number: NTR NL 7818

DEKRA Certification B.V.



H.R.M. Barends
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

CCA
CENELEC CERTIFICATION AGREEMENT
ACCORD DE CERTIFICATION DU CENELEC

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra-product-safety.com Company registration 09085396

Annex

CCA

CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CELENEC

Ref. no. NTR NL 7818

Page 1 of 1

Product data

Product	: built-in switch
Trade name(s)	: ETI
Type(s)/model(s)	: SV xyy (x – number of poles, yy – rated current)
Number of poles	: 1p, 2p, 3p, 4p
Rated operational voltage (Ue)	: 230 V (1p), 400 V (2p, 3p, 4p)
Rated insulation voltage (Ui)	: 440 V
Rated impulse withstand voltage (Uimp)	: 4 kV
Rated operational current (Ie)	: 16 A, 25 A, 40 A
Rated frequency	: 50/60 Hz
Conventional free air thermal current (Ith)	: identical to Ie
Connection capacity	: 1,0 mm ² - 10 mm ² rigid and flexible
Utilization category	: AC-23B
Rated short-time withstand current (Icw)	: 600 A – 1 s
Rated short-time making capacity (Icm)	: 500 A
Rated conditional short-circuit current	: 2 kA when protected with fuse-links limiting the cut-off current to maximum 2,235 kA and the Joule integral to a maximum of 7,348 kA ² s. fuse-links during tests: ETI DIII 50 A / 500 Vac / gL/gG
Suitability for isolation	: not suitable